

File Original and First Copy with
Department of Ecology
Second Copy—Owner's Copy
Third Copy—Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No.

214768

31/2E/32E

Water Right Permit No.

(1) OWNER: Name TERONDA WEST Address PO. 30 GREEN BANK WA

(2) LOCATION OF WELL: County ISLAND SW & NW 1/4 Sec 32 T31 N., R2E W.M.

(2a) STREET ADDRESS OF WELL (or nearest address) Highway 20 GREEN BANK WA 98253

(3) PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal ☐
☐ Irrigation ☐ Test Well ☒ Other ☐
☐ DeWater

(4) TYPE OF WORK: Owner's number of well (if more than one) 2
Abandoned ☐ New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 306 feet. Depth of completed well 306 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from 0 ft. to 291 1/2 ft.
Welded ☒ " Diam. from _____ ft. to _____ ft.
Liner installed ☐ " Diam. from _____ ft. to _____ ft.
Threaded ☐ " Diam. from _____ ft. to _____ ft.

Perforations: Yes ☐ No ☒

Type of perforator used _____

SIZE of perforations _____ in. by _____ in.

_____ perforations from _____ ft. to _____ ft.

_____ perforations from _____ ft. to _____ ft.

_____ perforations from _____ ft. to _____ ft.

Screens: Yes ☒ No ☐

Manufacturer's Name COOK

Type STAINLESS Model No. _____

Diam. 6 Slot size 15 from 291 ft. to 296 ft.

Diam. 6 Slot size 10 from 296 ft. to 306 ft.

Gravel packed: Yes ☐ No ☒ Size of gravel _____

Gravel placed from _____ ft. to _____ ft.

Surface seal: Yes ☒ No ☐ To what depth? 18 ft.

Material used in seal BENTONITE

Did any strata contain unusable water? Yes ☐ No ☒

Type of water? _____ Depth of strata _____

Method of sealing strata off _____

(7) PUMP: Manufacturer's Name _____

Type: _____ H.P. _____

(8) WATER LEVELS: Land-surface elevation above mean sea level _____ ft.

Static level 269 ft. below top of well Date 6 93

Artesian pressure _____ lbs. per square inch Date _____

Artesian water is controlled by _____ (Cap. valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☒ No ☐ If yes, by whom? Bob's Pumps

Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.

" " " "

" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time Water Level Time Water Level Time Water Level

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
SANDY	0	4
HARD PAN	4	62
CLAY	62	128
HARD SAND + GRAVEL	128	231
HARD PAN	231	260
SAND + GRAVEL MIX	260	284
CLAYER SAND	284	306

RECEIVED

JUL 09 1993

DEPT. OF ECOLOGY

Work started JUNE 28, 1993 Completed July 7, 1993

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME WHIDBEY DRILLERS (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)

Address OAK HARBOUR WA 98277

(Signature) John Jahn License No. 129 (WELL DRILLER)

Contractor's Registration No. WA10209MM Date July 7, 1993

(USE ADDITIONAL SHEETS IF NECESSARY)